

MONTGOMERY COLLEGE STUDENT SERVICES CENTER

ROCKVILLE, MD

Building and Plant Energy & Emissions Analysis

Technical information courtesy of James Posey Associates



Interior Rendering – Courtesy of Cho Benn Holback + Associates, Inc

Architectural Engineering 481W | Senior Thesis

Technical Report 2

Casey Zarger | Mechanical

Dr. James Freihaut | Faculty Advisor

<http://clzarger.wixsite.com/thesis>

Table of Contents

Executive Summary.....	3
Building Overview	3
Building Mechanical System Overview	5
Building Load Estimation	6
Design Conditions and Assumptions.....	6
Location.....	6
Building Construction.....	6
Electrical Service – Normal Power	7
Electrical Service – Emergency Power	8
Mechanical System Equipment.....	8
People Load.....	8
Load Calculation Results Commentary	9
Energy Consumption and Operating Costs	12
Energy Consumption.....	12
Annual Energy Cost Consumption	12
End Use Energy Consumption Breakdown	13
Monthly Electricity Consumption	14
Emissions.....	16
Annual Operating Costs	17
Fuel Consumption Costs	17
Monthly & Annual Energy Cost.....	17
Building Utility Cost per Square Foot.....	18
References:	19
Appendix:	20
Trace.....	20
Emission Factors for On-Site Combustion in a Commercial Boiler	35
Total Emission Factors for Delivered Electricity.....	35

Executive Summary

This report focuses on identifying major characteristics of the building's mechanical system, constructing and analyzing a load calculation model of the proposed design, and calculating annual energy consumption, monthly and yearly utility costs, and yearly particulate emissions. Design errors should be discovered and corrected as a result of this analysis.

The design documents were inspected for miscellaneous load sources, lighting densities, and other information for the load model constructed in Trane TRACE 700. Trace room templates were used as necessary in order to group room types to save time. Assumptions and the results from the Trace model are stated in this report. These findings are compared to the design engineer's model, which was also created in Trace.

This report also analyzes overall energy consumption, cost, and yearly emissions of the building. Charts and analysis of the results are included. These charts show building component loads, major sources of energy consumption, and total amount of emissions from those loads.

Building Overview

The Student Services Center is being designed and constructed by Montgomery College to replace its existing facility. The new building will house various student services, intake functions and programs serving students. It will also contain one academic department (school of education), administrative offices, the campus security office and a central plant operation serving both this building and the campus. The proposed building will consist of four stories above grade and a basement, and will contain 70,227 nsf and 128,004 gsp. The mechanical equipment will be located on the roof and in the basement. Each department is located within the building such that they remain a cohesive unit on the same floor and near other departments that work together. An emphasis was put on making the space inviting and easy to navigate for students. A large atrium on the first floor has a welcome center to aid students with questions and direct them to whatever department they'd like to visit. The building will be located at the end of the mall that runs the NS length of the campus. Glazing on the southern exterior will create an appealing gateway to the campus.



Figure 1. Building Floor Plan – Courtesy of Cho Benn Holback + Associates, Inc

The main mechanical room is located on the basement level, which contains two water cooled chillers, five boilers, eleven pumps, and a network of piping and ducts. Two custom air handlers are located in on the roof, and they both serve a single main chase that travels the height of the building. A two-cell cooling tower and VRF units are also located on the roof.




Figure 2. Mechanical Room Drawing – Courtesy of James Posey Associates

Building Mechanical System Overview

The heating water will be supplied by a new boiler plant with five high-efficiency condensing boilers, with an additional two boilers for redundancy, based on the AERCO BMK-6000 boilers. The boiler plant will be located in the basement mechanical room. The heating plant will have a dedicated primary, variable secondary, and variable tertiary system. Inline primary pumps for each boiler are anticipated. Three pumps sized for 50 percent of the flow will serve the secondary campus side, while three additional pumps sized at 50 percent of the flow will serve the tertiary pumps for the building. The new campus heating water system is anticipated to match the existing campus supply and return temperatures; 170 degrees F heating water supply, and 140 degrees F heating water return.

Campus chilled water is currently generated and distributed in the basement of the Humanities building. The chilled water for the Student Services Center will be supplied by two new water cooled chillers and cooling towers. These satellite chillers will be located in the Student Services Center's basement mechanical room, while the cooling towers will be located on the roof. The chillers will be based upon the Daiken Maglev Centrifugal chiller with variable frequency drive.

Two variable air volume air handling units will serve the Student Services Center. They will be equipped with 2-inch flat MERV 8 pre-filters, 12-inch cartridge type MERV 13 final filters, heating water preheat coils, chilled water cooling coils, and direct-drive plenum-type supply and return fans.

Single-duct VAV supply air terminal units with hydronic heating coils are anticipated for providing both space temperature and ventilation control for the building. A dedicated VAV terminal unit will be provided for each classroom, adjunct suite, conference room, corner office, department chair office, and specialty spaces. A single VAV terminal unit will support three or more interior offices, or perimeter offices with a common exposure. Dedicated and redundant ductless split systems and VAV terminal units will serve elevator machine rooms, IT rooms, and security closets.

Building Load Estimation

Trane Trace was used to construct an accurate model of Montgomery College Student Services Center. The design engineer also used Trane Trace. The assumptions to construct the load model are stated below, along with occupancies, glazing properties, ventilation rates, wall constructions, weather information, electrical information, and other miscellaneous conditions. The results are then compared to those of the designer.

Design Conditions and Assumptions

Location

Montgomery College Student Services Center is located in Rockville, MD. This location is Zone 4A in ASHRAE 90.1 – 2007 and is defined as mixed-humid from Table B-4. The climate data is taken from the 2009 ASHRAE Fundamentals Handbook.

Season	Dry Bulb (°F)	Mean Coincident Wet Bulb (°F)
Summer	94	75.2
Winter	12.9	

Table 1. ASHRAE 2009 Fundamentals Handbook Rockville, MD Climate Data

Season	Dry Bulb (°F)	Mean Coincident Wet Bulb (°F)
Summer	95	78
Winter	0	

Table 2. Climate Design Data Used by Designer

As seen in Tables 1 & 2, all design conditions used by the designer were more conservative than those given in the 2009 ASHRAE Fundamentals Handbook. The summer dry bulb condition design point is 1°F higher, the MCWB condition is 2.8°F higher, and the winter design dry bulb condition is 12.9°F lower.

Building Construction

The same U-value was used throughout the building for each of these components during design and energy modeling.

Construction	Description	U-value (BTU/(hr*SF*°F))	SC
Roof	built-up roof, high albedo cap sheet, 2-ply of modified bitumen membrane, self-adhering base layer, cover board and R-25 rigid polyisocyanurate insulation	0.04	-
Walls	4" masonry veneer, 4" cavity, 2" rigid insulation; air/water barrier and 8" CMU back up	0.0526	-
Glazing	1" insulated glazing units held in thermally-broken glazed aluminum curtainwall frames, low-e coatings	0.29	0.39

Table 3. Building Construction

Electrical Service – Normal Power

Pepco will provide a new 3000 ampere service with a pad-mounted utility transformer on the west side of the building. This transformer will feed a new main distribution panelboard rated at 3000A, 480Y/277V, 3-phase, 4 wire, with bolt-on type branch circuit breakers. Building service will be provided at 480Y/277V.

Design voltages will be as follows:

Item	Voltage
Service entrance	480Y/277 volt, 3-phase, 4 wire
Motors ½ HP and higher	480 volt, 3-phase, 3 wire
Motors smaller than ½ HP	277 volt, 1-phase
Lighting systems	277 volt, 1-phase
General receptacles	120 volt, 1-phase
Computer receptacles	120 volt, 1-phase

Table 4. Design Voltages for Normal Power

Design loads were developed as follows:

Load type	Unitary Load (W/sf)
Lighting	0.62
General receptacles	2.00
Computer receptacles	4.00
Mechanical equipment	8.00
Total	14.62

Table 5. Design Loads for Normal Power

Electrical Service – Emergency Power

Design voltages for the building's emergency power generation system will be 480Y/277 volt, 3-phase, 4 wire for mechanical equipment, 277 volt for lighting, and 120 volt for miscellaneous loads.

Load Type	Connected Load (kW)	Demand Load (kW)
Fire Pump (75HP)	69.0	69.0
Mechanical	39.8	39.8
Egress Lighting	31.9	31.9
Elevator	26.9	26.9
MDF/IDF Rooms	17.0	17.0
Receptacles	12.7	11.4
Fire Alarm/Security	2.0	1.6
Total	199.3	197.5

Table 6. Loads for Emergency Power

Mechanical System Equipment

Cooling

The cooling load will be met by two water-cooled chillers and cooling towers. The chillers will be located in the basement mechanical room, and the cooling towers will be located on the roof. They will be based on the Daiken Maglev Centrifugal chiller with variable frequency drive.

Heating

The heating load will be met by a new boiler plant consisting of five high-efficiency condensing boilers, with two additional boilers for redundancy, based on AERCO BMK-6000 boilers. They will be located in the basement mechanical room, and the plant will have a dedicated primary, variable secondary, and variable tertiary system.

Air Side

Two custom variable air volume air handling units will serve the Student Services Center and will be located on the roof. Single-duct VAV supply air terminal units with hydronic heating coils are anticipated for both space temperature and ventilation control for the building.

People Load

Space occupancies were determined to be as follows:

Space Type	Weekday Schedule (M-F)	Saturday Only
Student Activity	8:00 am to 10:00 pm	8:00 am to 12:00 pm (reduced occupancy)
Offices/ Meeting Areas	8:00 am to 5:00 pm	No occupancy
Classroom Areas	8:00 am to 10:00 pm	8:00 am to 12:00 pm (reduced occupancy)

Table 7. Occupancy Schedule

Ventilation rates were determined to be as follows:

Space Type	Design Ventilation Rate
Corridors	0.06 cfm/square foot
Classrooms & Computer Labs	10 cfm/person + 0.10 cfm/square foot
Office & Conference Spaces	5 cfm/person + 0.06 cfm/square foot
Multipurpose Assembly Spaces	5 cfm/person + 0.06 cfm/square foot
Lounges & Lobbies	5 cfm/person + 0.06 cfm/square foot

Table 8. Ventilation Rates

Heat gain of equipment, lighting, and people were determined to be as follows:

Space	Equipment (watts)	Lighting (watts/ft ²)	People (250 btu/hr sensible per person)
Computer Labs	100	0.6	33
Offices	100	0.6	1
Conference Room	500	0.6	8
Lobby/Lounge Areas	0	0.6	50
Corridors	0	0.6	ft ² per person
Rest Rooms/ Storage Rooms	0	0.6	0
Data/IT Rooms	10,500	0.6	0
MDF Room	26,000	0.6	0

Table 9. Miscellaneous Heat Gains

Load Calculation Results Commentary

The energy model was created by modeling the building space geometry in Revit, exporting a GBXML file, and importing that same GBXML file into Trane Trace 700. Zones were modeled and sorted into three systems, a VAV system, a heating only system, and a transient system. The VAV system includes most of the zones, including offices, lockers, electrical rooms, restrooms, bathrooms, work rooms, IDF/MDF, classrooms, and testing rooms. The heating only system includes the mechanical room, fire pump room, storage spaces, stairs, and the vestibule. The transient system includes storage, elevator machine rooms, showers, and other similar intermediate spaces.

The design engineer had higher design values than those calculated for this report. In all cases, it seems that the designer applied safety factors to their calculations. There could also be errors in one or both of the calculations done by either party as well, which would account for the load calculation differences. In addition, load calculation software is not completely accurate and only serves as a design guide. Actual energy usage must be taken retroactively from existing buildings to get a better sense of the energy use of certain building types. The building has a much higher required cooling load, with almost double the cooling CFM required. The occupancies of the building and internal loading decrease the required heating load during winter, which is a main contributor to the cooling load dominated building.

Air Handler	Type	Cooling Airflow (CFM)	Tons	Heating Airflow (CFM)	MBh
AHU-1	VAV	42942	176.8	15271.1	715.7
AHU-2	VAV	42942	176.8	15271.1	715.7
AHU-3	Packaged Vertical	1489.2	11.9	1489.2	64.6
CUH-1	Cabinet Unit Heater	-	-	515.1	25.84
CUH-2	Cabinet Unit Heater	-	-	515.1	25.84
CUH-3	Cabinet Unit Heater	-	-	515.1	25.84
CUH-4	Cabinet Unit Heater	-	-	515.1	25.84
CUH-5	Cabinet Unit Heater	-	-	515.1	25.84
CUH-6	Cabinet Unit Heater	-	-	515.1	25.84
PUH-1	Propeller Unit Heater	-	-	642.6	15.98
PUH-2	Propeller Unit Heater	-	-	642.6	15.98
PUH-3	Propeller Unit Heater	-	-	642.6	15.98
PUH-4	Propeller Unit Heater	-	-	642.6	15.98
PUH-5	Propeller Unit Heater	-	-	642.6	15.98
PUH-6	Propeller Unit Heater	-	-	714	20.06
PUH-7	Propeller Unit Heater	-	-	642.6	15.98
PUH-8	Propeller Unit Heater	-	-	714	20.06
PUH-9	Propeller Unit Heater	-	-	642.6	15.98
PUH-10	Propeller Unit Heater	-	-	642.6	15.98
Total	-	87,373.2	365.5	41,690.8	1,819

Table 10. Load Calculations

Air Handler	Type	Cooling Airflow (CFM)	Tons	Heating Airflow (CFM)	MBh
AHU-1	VAV	48,000	198	17,070	800
AHU-2	VAV	48,000	198	17,070	800
AHU-3	Packaged Vertical	1,000	7.96	1,000	43
CUH-1	Cabinet Unit Heater	-	-	505	25.3
CUH-2	Cabinet Unit Heater	-	-	505	25.3
CUH-3	Cabinet Unit Heater	-	-	505	25.3
CUH-4	Cabinet Unit Heater	-	-	505	25.3
CUH-5	Cabinet Unit Heater	-	-	505	25.3
CUH-6	Cabinet Unit Heater	-	-	505	25.3
PUH-1	Propeller Unit Heater	-	-	630	15.7
PUH-2	Propeller Unit Heater	-	-	630	15.7
PUH-3	Propeller Unit Heater	-	-	630	15.7
PUH-4	Propeller Unit Heater	-	-	630	15.7
PUH-5	Propeller Unit Heater	-	-	630	15.7
PUH-6	Propeller Unit Heater	-	-	700	19.6
PUH-7	Propeller Unit Heater	-	-	630	15.7
PUH-8	Propeller Unit Heater	-	-	700	19.6
PUH-9	Propeller Unit Heater	-	-	630	15.7
PUH-10	Propeller Unit Heater	-	-	630	15.7
Total	-	99,000	404	44,610	1,959.6

Table 11. Design Engineer's Load Calculations

Energy Consumption and Operating Costs

Energy Consumption

Annual Energy Cost Consumption

Figure 1 shows the distribution of the energy consumption for each component of Montgomery College Student Services Center. Receptacles by far consume the most energy annually, with cooling, lighting, and heating following. Figure 2 shows the data in the form of a pie chart in order to provide another way to visualize the data.




Figure 1. Annual Energy Cost Comparison Bar Graph




Figure 2. Annual Energy Cost Comparison Pie Chart

End Use Energy Consumption Breakdown

The building's distribution of energy usage and demand across a variety of equipment is shown below. The total energy usage is estimated at 1,800,000 kWh and the total demand is estimated at 820 kW.




Figure 3. Energy Use Bar Graph




Figure 4. Energy Use Pie Chart




Figure 5. Energy Demand Bar Graph




Figure 6. Energy Demand Pie Chart

Monthly Electricity Consumption

Figure 7 displays the monthly electricity consumption of the building. The building load is dominated by the utility load, which includes the high receptacle load, as well as the cooling load. A bell curve peaking in July would have been expected, but according to the model this is not the case. The monthly HVAC electrical consumption is displayed in Figure 8, with the cooling load dominating the energy consumption. Utility loads dominate the annual energy consumption, as seen in figure 9. Gas consumption (shown in figure 10), contributes only a small amount to the energy usage of the building.




Figure 7. Monthly Electricity Consumption




Figure 8. Monthly HVAC Electrical Consumption




Figure 9. Annual Electricity Consumption




Figure 10. Monthly Gas Consumption

Emissions

There is little environmental impact of the Montgomery College Student Services Center. Yearly emissions for the building are approximately 6,482,686 million pounds of CO₂, which is within safe limits. See Table 11 and the Appendix for emission factors used from the National Renewable Energy Laboratory, 2007 (NREAL).

Pollutant	Electricity Rate (lb/kWh)	Natural Gas Rate (lb/MCF)	Electricity (kWh/yr)	Natural Gas (MCF/yr)	Total Emissions (lb/yr)
CO2e	1.74	0.0123	1800000	1634	3132020
CO2	1.64	0.0122	1800000	1634	2952020
CH4	0.00359	0.0025	1800000	1634	6466.1
N2O	0.000087	0.0025	1800000	1634	160.7
NOX	0.003	0.111	1800000	1634	5581.4
SOX	0.00857	0.000632	1800000	1634	15427.0
CO	0.000854	0.0933	1800000	1634	1689.7
TNMOC	0.0000726	0.00613	1800000	1634	140.7
Lead	0.000000139	0.0000005	1800000	1634	0.25
Mercury	3.36E-08	0.000000026	1800000	1634	0.06
PM10	0.0000926	0.0084	1800000	1634	180.4
Solid Waste	0.205	0	1800000	1634	369000

Table 12. Annual Emissions

Annual Operating Costs

Fuel Consumption Costs

Data for fuel consumption costs was taken from March 2014 EIA reports for natural gas and July 2015 EIA reports for electricity.

Source	Rate	Unit	Cost
Electricity	0.1122	\$/kWh	201,960
Natural Gas	1.01	\$/therm	1,650

Table 13. Fuel Consumption Costs

Monthly & Annual Energy Cost

Data for monthly and annual fuel costs of electricity and gas are shown below in figures 11 and 12, respectively. This building is dominated by electric usage, due mainly to the influence of the electric chillers. Natural gas is only used for heating, so its usage is much lower during the summer months.




Figure 11. Monthly Energy Cost




Figure 12. Annual Energy Cost

Building Utility Cost per Square Foot

By dividing the square footage of the building by the yearly cost of energy consumption, the total cost per square foot could be calculated. The results are displayed below in Table 14.

Building ft ²	Cost/yr	Cost/(ft ² *yr)
128,000	203,610	1.59

Table 14. Building Utility Cost per Square Foot

References:

ANSI/ASHRAE. (2007). *Standard 62.1-2007, Ventilation for Acceptable Indoor Air Quality*. Atlanta, GA. American Society of Heating Refrigeration and Air Conditioning Engineers, Inc.

ANSI/ASHRAE. (2007). *Standard 90.1-2007, Ventilation for Buildings Except Low Rise Residential*. Atlanta, GA. American Society of Heating Refrigeration and Air Conditioning Engineers, Inc.

ASHRAE (2009). 2012 ASHRAE Handbook – Fundamentals. Atlanta, GA: American Society of Heating Refrigeration and Air Conditioning Engineers, Inc.

Trane Trace 700

Montgomery College Student Services Center Construction Documents, James Posey Associates, 2016

Appendix:

Trace

EQUIPMENT ENERGY CONSUMPTION

By ACADEMIC

Alternative: 1 Proposed

----- Monthly Consumption -----

Equipment - Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct
Lights										
Electric (kWh)	13,786.4	12,463.2	14,466.9	13,231.9	14,126.7	7,735.7	7,831.0	8,009.4	13,231.9	14,126.7
Peak (kW)	45.9	45.9	45.9	45.9	45.9	25.5	25.5	25.5	45.9	45.9
Misc. Ld										
Electric (kWh)	49,975.6	45,181.5	52,595.1	47,941.0	51,285.4	25,550.8	25,929.7	26,448.6	47,941.0	51,285.3
Peak (kW)	161.1	161.1	161.1	161.1	161.1	80.5	80.5	80.5	161.1	161.1
Cooling Coil Condensate										
Recoverable Water (1000gal)	0.0	0.0	0.0	0.1	0.6	0.0	0.0	0.0	0.8	0.0
Peak (1000gal/Hr)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Bsu 1: JPA - K12 - Elevator										
Electric (kWh)	582.8	527.3	638.3	555.0	610.5	610.5	555.0	638.3	555.0	610.5
Peak (kW)	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5
Bsu 2: JPA - K12 - Domestic Water										
Gas (therms)	1.4	1.2	1.5	1.3	1.4	1.4	1.3	1.5	1.3	1.4
Peak (therms/Hr)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Cpl 1: District Chilled Water [Sum of dsn coil capacities=283.0 tons]										
District Chilled Water [Clg Nominal Capacity/F.L.Rate=283.0 tons / 313.8 kW] (Cooling Equipment)										
Electric (kWh)	85.6	73.7	21.5	10,312.0	32,388.6	38,124.4	49,297.6	44,487.0	41,290.9	10,934.2
Peak (kW)	2.5	3.1	85.6	104.8	172.9	190.9	225.2	207.1	216.8	110.5
MZ packaged rooftop cond fan [Design Heat Rejection/F.L.Rate=372.2 tons / 31.27 kW]										
Electric (kWh)	10.7	9.2	2.7	1,356.0	4,053.6	4,459.5	5,608.8	5,121.7	5,136.6	1,443.0
Peak (kW)	0.3	0.4	11.4	13.3	20.2	20.6	23.5	21.9	24.4	14.0
JPA - 90.1-10 Var Vol Pump w Min Flow [F.L.Rate=12.45 kW] (Misc Accessory Equipment)										
Electric (kWh)	154.4	92.1	29.9	707.3	1,229.1	1,419.5	1,497.5	1,381.8	1,425.2	620.1
Peak (kW)	2.5	2.5	2.5	2.5	5.3	5.3	6.8	5.9	7.7	2.8
Cntl panel & interlocks - 0.1 KW [F.L.Rate=0.10 kW] (Misc Accessory Equipment)										
Electric (kWh)	6.2	3.7	1.2	28.4	49.1	57.0	57.0	54.9	50.7	24.9
Peak (kW)	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1

Project Name: Montgomery College Student Center
Dataset Name: 6352 - ENERGY-062415.TRC

TRACE® 700 v6.3.2 calculate
Alternative - 1 Equipment Energy C

EQUIPMENT ENERGY CONSUMPTION By ACADEMIC

Alternative: 1 Proposed

----- Monthly Consumption -----

Equipment - Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct
Cpl 1: District Chilled Water [Sum of dsn coil capacities=283.0 tons]										
JPA - Variable Volume Pump 30% Min [F.L.Rate=9.94 kW] (Cooling Plant Circulation Pump)										
Electric (kWh)	154.1	92.0	29.8	705.9	1,220.5	1,416.8	1,419.8	1,364.6	1,315.6	618.9
Peak (kW)	2.5	2.5	2.5	2.5	4.2	4.1	5.4	4.7	6.2	2.5
Cpl 2: No Cooling [Sum of dsn coil capacities=0 tons]										
Hpl 1: Boiler [Sum of dsn coil capacities=2,281 mbh]										
Boiler [Nominal Capacity/F.L.Rate=2,281 mbh / 25.35 Therms] (Heating Equipment)										
Gas (therms)	3,989.9	2,909.7	1,918.7	892.1	7.1	1.1	0.6	0.9	5.1	1,065.4
Peak (therms/Hr)	13.5	12.4	9.6	5.8	0.5	0.1	0.1	0.1	0.4	6.6
JPA - Variable Volume Pump 30% Min [F.L.Rate=14.91 kW] (Misc Accessory Equipment)										
Electric (kWh)	2,776.7	2,505.6	2,658.4	2,356.4	797.9	171.5	78.3	130.5	421.3	2,151.4
Peak (kW)	4.1	3.7	3.7	3.7	3.7	3.7	3.7	3.7	3.7	3.7
Boiler forced draft fan [F.L.Rate=2.28 kW] (Misc Accessory Equipment)										
Electric (kWh)	1,697.6	1,533.3	1,626.9	1,442.1	488.3	105.0	47.9	79.9	257.8	1,316.6
Peak (kW)	2.3	2.3	2.3	2.3	2.3	2.3	2.3	2.3	2.3	2.3
Cntl panel & interlocks - 0.5 KW [F.L.Rate=0.50 kW] (Misc Accessory Equipment)										
Electric (kWh)	372.0	336.0	356.5	316.0	107.0	23.0	10.5	17.5	56.5	288.5
Peak (kW)	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
Hpl 2: No heat [Sum of dsn coil capacities=0.00 mbh]										
Cntl panel & interlocks - 0.5 KW [F.L.Rate=0.50 kW] (Misc Accessory Equipment)										
Electric (kWh)	305.5	322.0	356.5	339.0	0.0	162.0	217.5	233.0	287.0	197.0
Peak (kW)	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
Sys 1: VAV										
JPA - 90.1 VAV Fan [DsnAirflow/F.L.Rate=111,847 cfm / 7.46 kW] (Main Clg Fan)										
Electric (kWh)	1,220.0	1,111.1	1,276.1	1,218.8	1,416.2	974.1	1,009.6	996.6	1,380.9	1,325.7
Peak (kW)	4.4	5.1	5.1	5.8	6.8	4.2	4.2	4.0	7.3	6.7
JPA - 90.1 VAV Fan [DsnAirflow/F.L.Rate=111,847 cfm / 3.73 kW] (Main Return Fan)										
Electric (kWh)	610.0	555.6	638.1	609.4	708.1	487.0	504.8	498.3	690.5	662.9
Peak (kW)	2.2	2.5	2.6	2.9	3.4	2.1	2.1	2.0	3.6	3.3

Project Name: Montgomery College Student Center
Dataset Name: 6352 - ENERGY-062415.TRC

TRACE® 700 v6.3.2 calculator
Alternative - 1 Equipment Energy C

EQUIPMENT ENERGY CONSUMPTION By ACADEMIC

Alternative: 2 Baseline

		----- Monthly Consumption -----									
Equipment - Utility		Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct
Lights											
Electric (kWh)		27,572.8	24,926.4	28,933.8	26,463.9	28,253.3	15,471.4	15,661.9	16,018.8	26,463.9	28,253.3
Peak (kW)		91.9	91.9	91.9	91.9	91.9	50.9	50.9	50.9	91.9	91.9
Misc. Ld											
Electric (kWh)		49,975.6	45,181.5	52,595.1	47,941.0	51,285.4	25,550.8	25,929.7	26,448.6	47,941.0	51,285.3
Peak (kW)		161.1	161.1	161.1	161.1	161.1	80.5	80.5	80.5	161.1	161.1
Cooling Coil Condensate											
Recoverable Water (1000gal)		0.7	0.5	0.5	0.4	0.4	0.1	0.1	0.1	0.7	0.5
Peak (1000gal/Hr)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Bsu 1: JPA - K12 - Elevator											
Electric (kWh)		582.8	527.3	638.3	555.0	610.5	610.5	555.0	638.3	555.0	610.5
Peak (kW)		3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5
Bsu 2: JPA - K12 - Domestic Water											
Gas (therms)		1.4	1.2	1.5	1.3	1.4	1.4	1.3	1.5	1.3	1.4
Peak (therms/Hr)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
<u>Cpl 1: Chilled Water [Sum of dsn coil capacities=306.0 tons]</u>											
Chilled Water [Clg Nominal Capacity/F.L.Rate=306.0 tons / 219.6 kW] (Cooling Equipment)											
Electric (kWh)		262.1	248.4	528.6	2,227.9	23,425.1	26,866.9	33,984.1	30,944.4	30,926.1	1,990.2
Peak (kW)		1.8	2.0	8.8	74.9	116.2	122.7	144.2	132.3	148.2	77.1
90.1 Min Cooling Tower [Design Heat Rejection/F.L.Rate=368.5 tons / 23.47 kW]											
Electric (kWh)		464.2	417.9	1,082.0	1,343.7	5,270.2	10,011.1	12,104.5	11,748.9	9,497.9	1,213.4
Peak (kW)		2.7	2.8	3.0	12.9	23.5	23.5	23.5	23.5	23.5	14.5
90.1 Min Cooling Tower											
Make Up Water (1000gal)		1.1	1.0	2.2	9.4	106.9	121.6	153.3	140.4	141.4	8.4
Peak (1000gal/Hr)		0.0	0.0	0.0	0.4	0.5	0.6	0.6	0.6	0.7	0.4
90.1-10 Min Var Vol Chilled Water Pump [F.L.Rate=13.47 kW] (Misc Accessory Equipment)											
Electric (kWh)		11.7	11.0	23.9	83.3	670.2	757.1	994.8	893.9	940.4	75.7
Peak (kW)		0.1	0.1	0.3	2.3	4.4	4.4	5.7	4.9	6.4	2.4

Project Name: Montgomery College Student Center
Dataset Name: 6352 - ENERGY-062415.TRC

TRACE® 700 v6.3.2 calculator
Alternative - 2 Equipment Energy C

EQUIPMENT ENERGY CONSUMPTION By ACADEMIC

Alternative: 2 Baseline

----- Monthly Consumption -----										
Equipment - Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct
<u>Cpl 1: Chilled Water [Sum of dsn coil capacities=306.0 tons]</u>										
90.1 Min CV Cond Water Pump [F.L.Rate=17.44 kW] (Misc Accessory Equipment)										
Electric (kWh)	3,139.9	2,808.5	7,029.9	7,849.7	8,564.9	8,617.3	9,070.8	8,913.8	8,547.5	7,029.9
Peak (kW)	17.4	17.4	17.4	17.4	17.4	17.4	17.4	17.4	17.4	17.4
Cntl panel & interlocks - 1 kW [F.L.Rate=1 kW] (Misc Accessory Equipment)										
Electric (kWh)	180.0	161.0	403.0	450.0	491.0	494.0	520.0	511.0	490.0	403.0
Peak (kW)	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
90.1 Min CV Chilled Water pump [F.L.Rate=0.00 kW] (Cooling Plant Circulation Pump)										
Electric (kWh)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
<u>Cpl 2: No Cooling [Sum of dsn coil capacities=0 tons]</u>										
<u>Hpl 1: Boiler [Sum of dsn coil capacities=2,664 mbh]</u>										
Boiler [Nominal Capacity/F.L.Rate=2,664 mbh / 32.49 Therms] (Heating Equipment)										
Gas (therms)	4,565.9	3,389.8	2,264.4	1,051.3	29.0	25.1	24.8	24.1	25.2	1,259.6
Peak (therms/Hr)	13.1	12.1	9.6	5.9	1.8	0.3	0.2	0.2	1.0	7.1
90.1 Min CV Hot Water pump [F.L.Rate=2.02 kW] (Misc Accessory Equipment)										
Electric (kWh)	1,508.3	1,380.6	1,457.7	1,212.8	431.3	380.6	429.2	419.1	390.8	1,320.1
Peak (kW)	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0
Make-up water - 5.18e-006 gal/btu (Misc Accessory Equipment)										
Make Up Water (1000gal)	10.3	9.3	9.9	8.3	2.9	2.6	2.9	2.9	2.7	9.0
Peak (1000gal/Hr)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Cntl panel & interlocks - 0.5 kW [F.L.Rate=0.50 kW] (Misc Accessory Equipment)										
Electric (kWh)	372.0	336.0	360.0	299.5	106.5	94.0	106.0	103.5	96.5	326.0
Peak (kW)	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
<u>Hpl 2: No Heat [Sum of dsn coil capacities=0.00 mbh]</u>										
Cntl panel & interlocks - 0.5 kW [F.L.Rate=0.50 kW] (Misc Accessory Equipment)										
Electric (kWh)	321.0	336.0	372.0	125.0	51.0	48.0	71.5	55.5	92.5	128.5
Peak (kW)	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
<u>Sys 1: Basement</u>										

Project Name: Montgomery College Student Center
Dataset Name: 6352 - ENERGY-062415.TRC

TRACE® 700 v6.3.2 calculate
Alternative - 2 Equipment Energy C

EQUIPMENT ENERGY CONSUMPTION

By ACADEMIC

Alternative: 2 Baseline

----- Monthly Consumption -----										
Equipment - Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct
Sys 1: Basement										
90.1-07 Min VAV AF Centrifugal [DsnAirflow/F.L.Rate=6,318 cfm / 6.85 kW (**Orig F.L.Rate=16.17 kW)] (Main Clg Fan)										
Electric (kWh)	1,250.3	1,233.6	1,678.6	1,528.8	1,697.9	690.7	703.6	725.1	1,610.3	1,625.8
Peak (kW)	5.3	6.9	6.9	6.9	6.9	2.6	2.7	2.7	6.9	6.9
Sys 4: First Floor										
90.1-07 Min VAV AF Centrifugal [DsnAirflow/F.L.Rate=24,278 cfm / 25.32 kW (**Orig F.L.Rate=28.19 kW)] (Main Clg Fan)										
Electric (kWh)	3,244.8	2,943.8	3,379.9	3,439.0	3,952.3	3,098.3	3,236.6	3,315.8	4,176.4	3,977.0
Peak (kW)	15.9	20.6	20.7	23.2	22.2	15.8	17.7	19.2	25.3	25.0
Sys 5: Second Floor										
90.1-07 Min VAV AF Centrifugal [DsnAirflow/F.L.Rate=25,278 cfm / 26.36 kW (**Orig F.L.Rate=32.09 kW)] (Main Clg Fan)										
Electric (kWh)	4,079.2	3,742.9	4,494.4	4,824.4	6,102.4	3,653.0	3,766.8	3,545.4	5,583.9	5,039.9
Peak (kW)	14.6	18.2	21.2	26.4	26.4	16.1	16.0	15.8	26.4	23.5
Sys 6: Third Floor										
90.1-07 Min VAV AF Centrifugal [DsnAirflow/F.L.Rate=29,042 cfm / 30.29 kW (**Orig F.L.Rate=34.94 kW)] (Main Clg Fan)										
Electric (kWh)	4,532.2	4,235.3	5,187.2	5,519.5	6,585.1	3,424.9	3,560.9	3,502.4	6,409.6	5,972.2
Peak (kW)	19.6	22.5	25.4	29.6	29.5	15.1	14.7	14.9	30.3	30.3
Sys 7: Fourth Floor										
90.1-07 Min VAV AF Centrifugal [DsnAirflow/F.L.Rate=28,739 cfm / 29.97 kW (**Orig F.L.Rate=33.22 kW)] (Main Clg Fan)										
Electric (kWh)	3,799.2	3,513.5	4,250.5	4,724.3	5,470.0	3,913.3	4,134.7	3,956.6	5,455.7	5,199.4
Peak (kW)	18.5	21.1	27.3	30.0	30.0	21.7	21.6	21.1	30.0	30.0

Project Name: Montgomery College Student Center
Dataset Name: 6352 - ENERGY-062415.TRC

TRACE® 700 v6.3.2 calculator
Alternative - 2 Equipment Energy C

System Checksums

By ACADEMIC

Heating Only

COOLING COIL PEAK					CLG SPACE PEAK					HEATING COIL PEAK				
Peaked at Time:		Mo/Hr: 0 / 0			Mo/Hr: 0 / 0		Mo/Hr: Heating Design							
Outside Air:		OADB/WB/HR: 0 / 0 / 0			OADB: 0		OADB: 10							
Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total	Space Sensible	Percent Of Total	Space Peak	Coil Peak	Percent						
Btu/h	Btu/h	Btu/h	(%)	Btu/h	(%)	Space Sens Btu/h	Tot Sens Btu/h	Of Total (%)						
Envelope Loads														
Skylite Solar	0	0	0	0	0	Skylite Solar	0	0.00						
Skylite Cond	0	0	0	0	0	Skylite Cond	0	0.00						
Roof Cond	0	0	0	0	0	Roof Cond	-1,650	3.85						
Glass Solar	0	0	0	0	0	Glass Solar	0	0.00						
Glass/Door Cond	0	0	0	0	0	Glass/Door Cond	-22,587	52.76						
Wall Cond	0	0	0	0	0	Wall Cond	-4,760	16.87						
Partition/Door	0	0	0	0	0	Partition/Door	-3,331	7.78						
Floor	0	0	0	0	0	Floor	-274	0.64						
Adjacent Floor	0	0	0	0	0	Adjacent Floor	0	0						
Infiltration	0	0	0	0	0	Infiltration	0	0.00						
Sub Total ==>	0	0	0	0	0	Sub Total ==>	-30,952	81.90						
Internal Loads														
Lights	0	0	0	0	0	Lights	0	0.00						
People	0	0	0	0	0	People	0	0.00						
Misc	0	0	0	0	0	Misc	0	0.00						
Sub Total ==>	0	0	0	0	0	Sub Total ==>	0	0.00						
Ceiling Load	0	0	0	0	0	Ceiling Load	-4,111	0.00						
Ventilation Load	0	0	0	0	0	Ventilation Load	0	0.66						
Adj Air Trans Heat	0	0	0	0	0	Adj Air Trans Heat	0	0						
Dehumid. Ov Sizing	0	0	0	0	0	Ov/Undr Sizing	-7,463	17.43						
Ov/Undr Sizing	0	0	0	0	0	Exhaust Heat	0	0.00						
Exhaust Heat	0	0	0	0	0	OA Preheat Diff.	0	0.00						
Sup. Fan Heat	0	0	0	0	0	RA Preheat Diff.	0	0.00						
Ret. Fan Heat	0	0	0	0	0	Additional Reheat	0	0.00						
Duct Heat Pkup	0	0	0	0	0	Underfir Sup Ht Pkup	0	0.00						
Underfir Sup Ht Pkup	0	0	0	0	0	Supply Air Leakage	0	0.00						
Supply Air Leakage	0	0	0	0	0									
Grand Total ==>	0	0	0	100.00	0	Grand Total ==>	-42,526	100.00						

COOLING COIL SELECTION										AREAS		HEAT		
Total Capacity	Sens Cap.	Coil Airflow	Enter DB/WB/HR	Leave DB/WB/HR	Gross Total		Glass							
ton	MBh	cfm	°F °F	gr/lb	°F °F	gr/lb	ft² (%)							
Main Clg	0.0	0.0	0 0.0 0.0	0.0	0.0 0.0 0.0	0.0	Floor	12,133			Main Htg			
Aux Clg	0.0	0.0	0 0.0 0.0	0.0	0.0 0.0 0.0	0.0	Part	3,260			Aux Htg			
Opt Vent	0.0	0.0	0 0.0 0.0	0.0	0.0 0.0 0.0	0.0	Int Door	0			Preheat			
							ExFlr	204			Humidif			
							Roof	948	0	0	Opt Vent			
							Wall	6,173	3,035	49	Total			
							Ext Door	0	0	0				

Project Name: Montgomery College Student Center
Dataset Name: 6352 - ENERGY-062415.TRC

TRACE® 700 v6.3.2
Alternative - 1 Sy

System Checksums

By ACADEMIC

Transient

COOLING COIL PEAK					CLG SPACE PEAK			HEATING COIL PEAK			
Peaked at Time:		Mo/Hr: 10 / 12			Mo/Hr: Sum of		Mo/Hr: Heating Design				
Outside Air:		OADB/WB/HR: 67 / 58 / 56			OADB: Peaks		OADB: 10				
	Space Sens. + Lat. Btu/h	Plenum Sens. + Lat. Btu/h	Net Total Btu/h	Percent Of Total (%)	Space Sensible Btu/h	Percent Of Total (%)	Space Peak Space Sens Btu/h	Coil Peak Tot Sens Btu/h	Percent Of Total (%)		
Envelope Loads											
Skylite Solar	0	0	0	0	0	0	0	0	0.00		
Skylite Cond	0	0	0	0	0	0	0	0	0.00		
Roof Cond	0	1,337	1,337	10	0	0	0	-492	23.88		
Glass Solar	13,605	0	13,605	102	13,605	97	0	0	0.00		
Glass/Door Cond	-2,489	0	-2,489	-18	-2,489	-18	-1,201	-1,201	58.36		
Wall Cond	-132	-45	-177	-1	-132	-1	-240	-314	15.24		
Partition/Door	-3,626	0	-3,626	-27	-3,626	-26	917	917	-44.56		
Floor	0	0	0	0	0	0	-47	-47	2.27		
Adjacent Floor	0	0	0	0	0	0	0	0	0		
Infiltration	0	0	0	0	0	0	0	0	0.00		
Sub Total ==>	7,378	1,292	8,670	65	7,378	52	-571	-1,136	55.19		
Internal Loads											
Lights	2,596	649	3,244	24	2,719	19	0	0	0.00		
People	0	0	0	0	0	0	0	0	0.00		
Misc	410	0	410	3	410	3	0	0	0.00		
Sub Total ==>	3,005	649	3,654	27	3,129	22	0	0	0.00		
Ceiling Load	2,151	-2,151	0	0	2,489	18	-551	0	0.00		
Ventilation Load	0	0	121	1	0	0	0	-169	8.21		
Adj Air Trans Heat	0	0	0	0	0	0	0	0	0		
Dehumid. Ov Sizing	0	0	0	0	0	0	-855	-855	41.53		
Ov/Undr Sizing	1,072	0	1,072	8	1,072	8	0	102	-4.94		
Exhaust Heat	0	-133	-133	-1	0	0	0	0	0.00		
Sup. Fan Heat	0	0	0	0	0	0	0	0	0.00		
Ret. Fan Heat	0	0	0	0	0	0	0	0	0.00		
Duct Heat PkUp	0	0	0	0	0	0	0	0	0.00		
Underflr Sup Ht PkUp	0	0	0	0	0	0	0	0	0.00		
Supply Air Leakage	0	0	0	0	0	0	0	0	0.00		
Grand Total ==>	13,606	-343	13,385	100.00	14,068	100.00	-1,977	-2,059	100.00		

COOLING COIL SELECTION								AREAS		HEATING COIL PEAK	
Total Capacity ton	Sens Cap. MBh	Coil Airflow cfm	Enter DB/WB/HR °F	°F	gr/lb	Leave DB/WB/HR °F	°F	Gross Total	Glass ft² (%)	Main Htg	Aux Htg
Main Clg	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Floor	3,059		
Aux Clg	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Part	1,200		
Opt Vent	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	0		
Total	0.0	0.0						ExFlr	75		
								Roof	514	0	0
								Wall	419	172	41
								Ext Door	0	0	0
										Humidif	Opt Vent
										Total	

Project Name: Montgomery College Student Center
Dataset Name: 6352 - ENERGY-062415.TRC

TRACE® 700 v6.3.2
Alternative - 1 Sy

System Checksums

By ACADEMIC

VAV

Variable Volume Ret

COOLING COIL PEAK					CLG SPACE PEAK					HEATING COIL PEAK				
Peaked at Time: Mo/Hr: 4 / 12					Mo/Hr: 9 / 12					Mo/Hr: Heating Design				
Outside Air: OADB/WB/HR: 68 / 57 / 52					OADB: 80					OADB: 10				
Envelope Loads	Space Sens. + Lat. Btu/h	Plenum Sens. + Lat. Btu/h	Net Total Btu/h	Percent Of Total (%)	Envelope Loads	Space Sensible Btu/h	Percent Of Total (%)	Envelope Loads	Space Peak Space Sens Btu/h	Coil Peak Tot Sens Btu/h	Percent Of Total (%)	Envelope Loads	Space Peak Space Sens Btu/h	Coil Peak Tot Sens Btu/h
Skylite Solar	0	0	0	0	0	0	0	Skylite Solar	0	0	0.00	Skylite Solar	0	0
Skylite Cond	0	0	0	0	0	0	0	Skylite Cond	0	0	0.00	Skylite Cond	0	0
Roof Cond	0	62,857	62,857	4	0	0	0	Roof Cond	0	-56,303	2.88	Roof Cond	0	-56,303
Glass Solar	551,747	0	551,747	34	600,841	39	600,841	Glass Solar	0	0	0.00	Glass Solar	0	0
Glass/Door Cond	-44,607	0	-44,607	-3	15,675	1	15,675	Glass/Door Cond	-300,995	-300,995	15.39	Glass/Door Cond	-300,995	-300,995
Wall Cond	-760	-877	-1,637	-0	9,110	1	9,110	Wall Cond	-49,708	-71,681	3.67	Wall Cond	-49,708	-71,681
Partition/Door	-9,375	0	-9,375	-1	-4,298	0	-4,298	Partition/Door	-10,746	-10,746	0.55	Partition/Door	-10,746	-10,746
Floor	0	0	0	0	0	0	0	Floor	-709	-709	0.04	Floor	-709	-709
Adjacent Floor	0	0	0	0	0	0	0	Adjacent Floor	0	0	0	Adjacent Floor	0	0
Infiltration	0	0	0	0	0	0	0	Infiltration	0	0	0.00	Infiltration	0	0
Sub Total ==>	497,005	61,980	558,985	34	621,330	41	621,330	Sub Total ==>	-362,158	-440,434	22.52	Sub Total ==>	-362,158	-440,434
Internal Loads					Internal Loads					Internal Loads				
Lights	110,473	27,618	138,092	8	110,473	7	110,473	Lights	0	0	0.00	Lights	0	0
People	413,218	0	413,218	25	229,498	15	229,498	People	0	0	0.00	People	0	0
Misc	549,251	0	549,251	33	549,251	36	549,251	Misc	0	0	0.00	Misc	0	0
Sub Total ==>	1,072,942	27,618	1,100,561	67	889,222	58	889,222	Sub Total ==>	0	0	0.00	Sub Total ==>	0	0
Ceiling Load	19,492	-19,492	0	0	18,436	1	18,436	Ceiling Load	-32,553	0	0.00	Ceiling Load	-32,553	0
Ventilation Load	0	0	-245,330	-15	0	0	0	Ventilation Load	0	0	0.00	Ventilation Load	0	0
Adj Air Trans Heat	0	0	0	0	0	0	0	Adj Air Trans Heat	0	0	0	Adj Air Trans Heat	0	0
Dehumid. Ov Sizing	0	0	0	0	0	0	0	Ov/Undr Sizing	0	0	0.00	Ov/Undr Sizing	0	0
Ov/Undr Sizing	0	0	0	0	0	0	0	Exhaust Heat	43,027	-2.20	-2.20	Exhaust Heat	43,027	-2.20
Exhaust Heat	0	-45,531	-45,531	-3	0	0	0	OA Preheat Diff.	-1,175,444	60.11	60.11	OA Preheat Diff.	-1,175,444	60.11
Sup. Fan Heat	0	0	182,808	11	0	0	0	RA Preheat Diff.	-44,927	2.30	2.30	RA Preheat Diff.	-44,927	2.30
Ret. Fan Heat	91,404	91,404	91,404	6	0	0	0	Additional Reheat	-337,778	17.27	17.27	Additional Reheat	-337,778	17.27
Duct Heat Pkup	0	0	0	0	0	0	0	Underfir Sup Ht Pkup	0	0.00	0.00	Underfir Sup Ht Pkup	0	0.00
Underfir Sup Ht Pkup	0	0	0	0	0	0	0	Supply Air Leakage	0	0.00	0.00	Supply Air Leakage	0	0.00
Supply Air Leakage	0	0	0	0	0	0	0	Grand Total ==>	-394,711	-1,955,557	100.00	Grand Total ==>	-394,711	-1,955,557
Grand Total ==>	1,589,440	115,980	1,642,898	100.00	1,528,989	100.00	1,528,989	Grand Total ==>	-394,711	-1,955,557	100.00	Grand Total ==>	-394,711	-1,955,557

COOLING COIL SELECTION								AREAS				HEA	
	Total Capacity ton	Capacity MBh	Sens Cap. MBh	Coil Airflow cfm	Enter DB/WB/HR °F	°F	gr/lb	Leave DB/WB/HR °F	°F	Gross Total	Glass ft² (%)	Main Htg	Aux Htg
Main Clg	136.9	1,642.9	1,606.6	102,829	76.1	62.5	62.2	61.3	57.1	103,825			
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	7,528			
Opt Vent	146.1	1,753.0	832.8	17,397	92.5	78.8	126.1	50.0	49.9	0			
Total	283.0	3,395.9											

	Floor	Part	Int Door	ExFlr	Roof	Wall	Ext Door	Main Htg	Aux Htg	Preheat	Reheat	Humidif	Opt Vent	Total
	103,825	7,528	0	471	24,456	40,074	0							
					0	17,240	0							
					0	43	0							

Project Name: Montgomery College Student Center
Dataset Name: 6352 - ENERGY-062415.TRC

TRACE® 700 v6.3.2
Alternative - 1 Sy

System Checksums

By ACADEMIC

Basement

System 7 - 2007 - Packaged RTU VAV Reh

COOLING COIL PEAK					CLG SPACE PEAK			HEATING COIL PEAK			
Peaked at Time:		Mo/Hr: 4 / 16			Mo/Hr: 9 / 16		Mo/Hr: Heating Design				
Outside Air:		OADB/WB/HR: 72 / 59 / 52			OADB: 84		OADB: 10				
Envelope Loads	Space Sens. + Lat. Btu/h	Plenum Sens. + Lat. Btu/h	Net Total Btu/h	Percent Of Total (%)	Space Sensible Btu/h	Percent Of Total (%)	Envelope Loads	Space Peak Space Sens Btu/h	Coil Peak Tot Sens Btu/h	Percent Of Total (%)	
Skylite Solar	0	0	0	0	0	0	Skylite Solar	0	0	0.00	
Skylite Cond	0	0	0	0	0	0	Skylite Cond	0	0	0.00	
Roof Cond	0	0	0	0	0	0	Roof Cond	0	0	0.00	
Glass Solar	0	0	0	0	0	0	Glass Solar	0	0	0.00	
Glass/Door Cond	0	0	0	0	0	0	Glass/Door Cond	0	0	0.00	
Wall Cond	0	0	0	0	0	0	Wall Cond	0	0	0.00	
Partition/Door	-9,375	0	-9,375	-7	-4,296	-3	Partition/Door	-10,746	-10,746	4.73	
Floor	0	0	0	0	0	0	Floor	-709	-709	0.31	
Adjacent Floor	0	0	0	0	0	0	Adjacent Floor	0	0	0	
Infiltration	0	0	0	0	0	0	Infiltration	0	0	0.00	
Sub Total ==>	-9,375	0	-9,375	-7	-4,296	-3	Sub Total ==>	-11,455	-11,455	5.05	
Internal Loads					Internal Loads						
Lights	39,290	9,822	49,112	36	39,290	28	Lights	0	0	0.00	
People	41,918	0	41,918	31	23,288	16	People	0	0	0.00	
Misc	79,957	0	79,957	59	79,957	56	Misc	0	0	0.00	
Sub Total ==>	161,164	9,822	170,987	126	142,534	100	Sub Total ==>	0	0	0.00	
Ceiling Load	4,128	-4,128	0	0	4,053	3	Ceiling Load	0	0	0.00	
Ventilation Load	0	0	-15,741	-12	0	0	Ventilation Load	0	0	0.00	
Adj Air Trans Heat	0	0	0	0	0	0	Adj Air Trans Heat	0	0	0	
Dehumid. Ov Sizing	0	0	0	0	0	0	Ov/Undr Sizing	0	0	0.00	
Ov/Undr Sizing	0	0	0	0	0	0	Exhaust Heat	7,968	-3.51		
Exhaust Heat	0	-14,994	-14,994	-11	0	0	OA Preheat Diff.	-166,428	73.32		
Sup. Fan Heat	0	0	4,516	3	0	0	RA Preheat Diff.	-27,145	11.96		
Ref. Fan Heat	0	0	0	0	0	0	Additional Reheat	-29,916	13.18		
Duct Heat Pkup	0	0	0	0	0	0	Underflr Sup Ht Pkup	0	0.00		
Underflr Sup Ht Pkup	0	0	0	0	0	0	Supply Air Leakage	0	0.00		
Supply Air Leakage	0	0	0	0	0	0	Grand Total ==>	-11,455	-226,976	100.00	
Grand Total ==>	155,917	-9,300	135,392	100.00	142,292	100.00	Grand Total ==>	-11,455	-226,976	100.00	

COOLING COIL SELECTION										AREAS		HEAT
Total Capacity ton	Capacity MBh	Sens Cap. MBh	Coil Airflow cfm	Enter DB/°F	WB/°F	HR gr/lb	Leave DB/°F	WB/°F	HR gr/lb	Gross Total	Glass ft² (%)	
Main Clg	13.0	155.7	123.6	6,096	78.9	61.2	54.7	54.3	52.2	54.4		Main Htg
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Aux Htg
Opt Vent	20.7	248.2	117.9	2,463	92.5	78.8	126.1	50.0	49.9	52.9		Preheat
Total	33.7	403.9										Reheat

				AREAS				HEAT
Floor	Part	Int Door	ExFlr	Roof	Wall	Ext Door	Total	
17,965	7,528	0	471	0	0	0		Main Htg
0	0	0	0	0	0	0		Aux Htg
0	0	0	0	0	0	0		Preheat
0	0	0	0	0	0	0		Reheat
0	0	0	0	0	0	0		Humidif
0	0	0	0	0	0	0		Opt Vent
0	0	0	0	0	0	0		Total

Project Name: Montgomery College Student Center
Dataset Name: 6352 - ENERGY-062415.TRC

TRACE® 700 v6.3.2
Alternative - 2 Sy

System Checksums

By ACADEMIC

First Floor

System 7 - 2007 - Packaged RTU VAV Reh

COOLING COIL PEAK					CLG SPACE PEAK			HEATING COIL PEAK			
Peaked at Time: Mo/Hr: 4 / 11 Outside Air: OADB/WB/HR: 65 / 56 / 51					Mo/Hr: 9 / 11 OADB: 78			Mo/Hr: Heating Design OADB: 10			
Envelope Loads	Space Sens. + Lat. Btu/h	Plenum Sens. + Lat. Btu/h	Net Total Btu/h	Percent Of Total (%)	Space Sensible Btu/h	Percent Of Total (%)		Space Peak Space Sens Btu/h	Coil Peak Tot Sens Btu/h	Percent Of Total (%)	
Skylite Solar	0	0	0	0	0	0		0	0	0.00	
Skylite Cond	0	0	0	0	0	0		0	0	0.00	
Roof Cond	0	753	753	0	0	0		0	-2,861	0.70	
Glass Solar	170,633	0	170,633	52	182,839	52		0	0	0.00	
Glass/Door Cond	-15,861	0	-15,861	-5	-1,424	21		-84,997	-84,997	22.45	
Wall Cond	577	204	781	0	3,807	1		-16,292	-22,641	5.98	
Partition/Door	0	0	0	0	0	0		0	0	0.00	
Floor	0	0	0	0	0	0		0	0	0.00	
Adjacent Floor	0	0	0	0	0	0		0	0	0	
Infiltration	0	0	0	0	0	0		0	0	0.00	
Sub Total ==>	155,349	957	156,306	48	188,070	54		-101,288	-110,299	29.13	
Internal Loads					Internal Loads						
Lights	45,772	11,443	57,215	17	45,772	13		0	0	0.00	
People	70,453	0	70,453	21	39,133	11		0	0	0.00	
Misc	72,928	0	72,928	22	72,928	21		0	0	0.00	
Sub Total ==>	189,153	11,443	200,596	61	157,833	45		0	0	0.00	
Ceiling Load	2,768	-2,768	0	0	2,957	1		-3,838	0	0.00	
Ventilation Load	0	0	-42,118	-13	0	0		0	0	0.00	
Adj Air Trans Heat	0	0	0	0	0	0		0	0	0	
Dehumid. Ov Sizing	0	0	0	0	0	0		0	0	0.00	
Ov/Undr Sizing	0	-2,046	-2,046	-1	0	0		0	3,521	-0.93	
Exhaust Heat			16,288	5					-193,927	51.22	
Sup. Fan Heat		0	0	0					-4,031	1.06	
Ret. Fan Heat		0	0	0					-73,857	19.51	
Duct Heat Pkup		0	0	0							
Underfir Sup Ht Pkup		0	0	0					0	0.00	
Supply Air Leakage		0	0	0					0	0.00	
Grand Total ==>	347,270	7,586	329,026	100.00	348,860	100.00		-105,126	-378,593	100.00	

COOLING COIL SELECTION								AREAS			HEA	
	Total Capacity ton	MBh	Sens Cap. MBh	Coil Airflow cfm	Enter DB/WB/HR °F °F gr/lb	Leave DB/WB/HR °F °F gr/lb		Gross Total	Glass ft² (%)		Main Htg	Aux Htg
Main Clg	31.5	378.4	323.7	21,988	74.9 62.2 62.5	61.6 56.5 59.4		Floor	22,538			
Aux Clg	0.0	0.0	0.0	0	0.0 0.0 0.0	0.0 0.0 0.0		Part	0			
Opt Vent	24.1	289.2	137.4	2,870	92.5 78.8 126.1	50.0 49.9 52.9		Int Door	0			
								ExFlr	0			
Total	55.6	667.6						Roof	1,130	0		
								Wall	9,639	3,711	39	
								Ext Door	0	0	0	
											Preheat	
											Reheat	
											Humidif	
											Opt Vent	
											Total	

Project Name: Montgomery College Student Center
Dataset Name: 6352 - ENERGY-062415.TRC

TRACE® 700 v6.3.2
Alternative - 2 Sy

By ACADEMIC

System 7 - 2007 - Packaged RTU VAV Reh

Project Name: Montgomery College Student Center
Dataset Name: 6352 - ENERGY-062415.TRC

System Checksums

By ACADEMIC

Heating Only

COOLING COIL PEAK					CLG SPACE PEAK			HEATING COIL PEAK			
Peaked at Time:		Mo/Hr: 0 / 0			Mo/Hr: 0 / 0		Mo/Hr: Heating Design		Mo/Hr: Heating Design		
Outside Air:		OADB/WB/HR: 0 / 0 / 0			OADB: 0		OADB: 10		OADB: 10		
	Space Sens. + Lat. Btu/h	Plenum Sens. + Lat. Btu/h	Net Total Btu/h	Percent Of Total (%)	Space Sensible Btu/h	Percent Of Total (%)		Space Peak Space Sens Btu/h	Coil Peak Tot Sens Btu/h	Percent Of Total (%)	
Envelope Loads											
Skylite Solar	0	0	0	0	0	0	Skylite Solar	0	0	0.00	
Skylite Cond	0	0	0	0	0	0	Skylite Cond	0	0	0.00	
Roof Cond	0	0	0	0	0	0	Roof Cond	0	-1,645	3.35	
Glass Solar	0	0	0	0	0	0	Glass Solar	0	0	0.00	
Glass/Door Cond	0	0	0	0	0	0	Glass/Door Cond	-29,628	-29,628	60.41	
Wall Cond	0	0	0	0	0	0	Wall Cond	-5,748	-8,711	17.76	
Partition/Door	0	0	0	0	0	0	Partition/Door	-3,331	-3,331	6.79	
Floor	0	0	0	0	0	0	Floor	-274	-274	0.56	
Adjacent Floor	0	0	0	0	0	0	Adjacent Floor	0	0	0	
Infiltration	0	0	0	0	0	0	Infiltration	0	0	0.00	
Sub Total ==>	0	0	0	0	0	0	Sub Total ==>	-38,981	-43,589	88.88	
Internal Loads											
Lights	0	0	0	0	0	0	Lights	0	0	0.00	
People	0	0	0	0	0	0	People	0	0	0.00	
Misc	0	0	0	0	0	0	Misc	0	0	0.00	
Sub Total ==>	0	0	0	0	0	0	Sub Total ==>	0	0	0.00	
Ceiling Load	0	0	0	0	0	0	Ceiling Load	-4,608	0	0.00	
Ventilation Load	0	0	0	0	0	0	Ventilation Load	0	-284	0.58	
Adj Air Trans Heat	0	0	0	0	0	0	Adj Air Trans Heat	0	0	0	
Dehumid. Ov Sizing	0	0	0	0	0	0	Ov/Undr Sizing	-5,170	-5,170	10.54	
Ov/Undr Sizing	0	0	0	0	0	0	Exhaust Heat	0	0	0.00	
Exhaust Heat	0	0	0	0	0	0	OA Preheat Diff.	0	0	0.00	
Sup. Fan Heat	0	0	0	0	0	0	RA Preheat Diff.	0	0	0.00	
Ret. Fan Heat	0	0	0	0	0	0	Additional Reheat	0	0	0.00	
Duct Heat Pkup	0	0	0	0	0	0	Underfir Sup Ht Pkup	0	0	0.00	
Underfir Sup Ht Pkup	0	0	0	0	0	0	Supply Air Leakage	0	0	0.00	
Supply Air Leakage	0	0	0	0	0	0					
Grand Total ==>	0	0	0	100.00	0	100.00	Grand Total ==>	-48,759	-49,043	100.00	

COOLING COIL SELECTION								AREAS			HEA				
	Total Capacity ton	MBh	Sens Cap. MBh	Coil Airflow cfm	Enter DB/WB/HR °F	°F	gr/lb	Leave DB/WB/HR °F	°F	gr/lb		Gross Total	Glass ft² (%)		
Main Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Floor	12,133		Main Htg	
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	3,260		Aux Htg	
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	0		Preheat	
											Ext Flr	204			
											Roof	948	0	Humidif	
											Wall	6,173	3,035	49	Opt Vent
											Ext Door	0	0	0	Total
Total	0.0	0.0													

Project Name: Montgomery College Student Center
Dataset Name: 6352 - ENERGY-062415.TRC

TRACE® 700 v6.3.2
Alternative - 2 Sy

System Checksums

By ACADEMIC

Second Floor

System 7 - 2007 - Packaged RTU VAV Reh

COOLING COIL PEAK					CLG SPACE PEAK			HEATING COIL PEAK			
Peaked at Time: Mo/Hr: 4 / 11					Mo/Hr: 9 / 11			Mo/Hr: Heating Design			
Outside Air: OADB/WB/HR: 65 / 56 / 51					OADB: 78			OADB: 10			
Envelope Loads	Space Sens. + Lat. Btu/h	Plenum Sens. + Lat. Btu/h	Net Total Btu/h	Percent Of Total (%)	Space Sensible Btu/h	Percent Of Total (%)		Space Peak Space Sens Btu/h	Coil Peak Tot Sens Btu/h	Percent Of Total (%)	
Skylite Solar	0	0	0	0	0	0		0	0	0.00	
Skylite Cond	0	0	0	0	0	0		0	0	0.00	
Roof Cond	0	1,686	1,686	0	0	0		0	-5,876	1.30	
Glass Solar	137,764	0	137,764	37	133,315	36		0	0	0.00	
Glass/Door Cond	-18,555	0	-18,555	-5	1,689	0		-99,550	-99,550	22.02	
Wall Cond	561	276	837	0	3,558	1		-14,638	-21,371	4.73	
Partition/Door	0	0	0	0	0	0		0	0	0.00	
Floor	0	0	0	0	0	0		0	0	0.00	
Adjacent Floor	0	0	0	0	0	0		0	0	0	
Infiltration	0	0	0	0	0	0		0	0	0.00	
Sub Total ==>	119,769	1,962	121,731	33	138,562	37		-114,187	-126,797	28.05	
Internal Loads					Internal Loads						
Lights	47,608	11,902	59,510	16	47,608	13		0	0	0.00	
People	89,303	0	89,303	24	49,613	13		0	0	0.00	
Misc	135,573	0	135,573	37	135,573	36		0	0	0.00	
Sub Total ==>	272,483	11,902	284,385	77	232,793	62		0	0	0.00	
Ceiling Load	2,829	-2,829	0	0	3,193	1		-4,893	0	0.00	
Ventilation Load	0	0	-51,587	-14	0	0		0	0	0.00	
Adj Air Trans Heat	0	0	0	0	0	0		0	0	0	
Dehumid. Ov Sizing	0	0	0	0	0	0		0	0	0.00	
Ov/Undr Sizing	0	0	0	0	0	0		0	4,448	-0.98	
Exhaust Heat	0	-1,608	-1,608	0	0	0		0	-237,852	52.61	
Sup. Fan Heat	0	17,767	17,767	5	0	0		0	-2,988	0.66	
Ref. Fan Heat	0	0	0	0	0	0		0	-88,876	19.68	
Duct Heat Pkup	0	0	0	0	0	0		0	0	0.00	
Underflr Sup Ht Pkup	0	0	0	0	0	0		0	0	0.00	
Supply Air Leakage	0	0	0	0	0	0		0	0	0.00	
Grand Total ==>	395,081	9,427	370,688	100.00	374,549	100.00		-119,081	-452,065	100.00	

COOLING COIL SELECTION										AREAS			HEA
	Total ton	Capacity MBh	Sens Cap. MBh	Coil Airflow cfm	Enter °F	DB/WB/HR °F	gr/lb	Leave DB/WB/HR °F	°F	gr/lb	Gross Total	Glass ft² (%)	
Main Clg	35.5	426.3	362.8	23,986	74.6	62.0	62.3	61.2	56.1	58.6	Floor	22,004	Main Htg
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0	Aux Htg
Opt Vent	29.6	354.7	168.5	3,520	92.5	78.8	126.1	50.0	49.9	52.9	Int Door	0	Preheat
											ExFlr	0	Reheat
											Roof	2,496	0
											Wall	9,946	4,347 44
											Ext Door	0	0 0
Total	65.1	781.0											Total

Project Name: Montgomery College Student Center
Dataset Name: 6352 - ENERGY-062415.TRC

TRACE® 700 v6.3.2
Alternative - 2 Sy

System Checksums

By ACADEMIC

Third Floor

System 7 - 2007 - Packaged RTU VAV Reh

COOLING COIL PEAK					CLG SPACE PEAK			HEATING COIL PEAK				
Peaked at Time: Outside Air: Mo/Hr: 4 / 12 OADB/WB/HR: 68 / 57 / 52					Mo/Hr: 9 / 12 OADB: 80			Mo/Hr: Heating Design OADB: 10				
Space Sens. + Lat. Btu/h	Plenum Sens. + Lat. Btu/h	Net Total Btu/h	Percent Of Total (%)		Space Sensible Btu/h	Percent Of Total (%)		Space Peak Space Sens Btu/h	Coil Peak Tot Sens Btu/h	Percent Of Total (%)		
Envelope Loads												
Skyline Solar	0	0	0	0	0	0	0	Skyline Solar	0	0	0.00	
Skyline Cond	0	0	0	0	0	0	0	Skyline Cond	0	0	0.00	
Roof Cond	0	0	0	0	0	0	0	Roof Cond	0	0	0.00	
Glass Solar	126,771	0	126,771	31	142,094	34	0	Glass Solar	0	0	0.00	
Glass/Door Cond	-12,187	0	-12,187	-3	5,068	1	0	Glass/Door Cond	-87,580	-87,580	19.43	
Wall Cond	2,458	1,006	3,464	1	6,484	2	0	Wall Cond	-16,740	-23,819	5.28	
Partition/Door	0	0	0	0	0	0	0	Partition/Door	0	0	0.00	
Floor	0	0	0	0	0	0	0	Floor	0	0	0.00	
Adjacent Floor	0	0	0	0	0	0	0	Adjacent Floor	0	0	0.00	
Infiltration	0	0	0	0	0	0	0	Infiltration	0	0	0.00	
Sub Total ==>	117,042	1,006	118,048	29	153,646	36	0	Sub Total ==>	-104,321	-111,399	24.71	
Internal Loads												
Lights	43,113	10,778	53,891	13	43,113	10	0	Lights	0	0	0.00	
People	91,328	0	91,328	23	50,738	12	0	People	0	0	0.00	
Misc	173,494	0	173,494	43	173,494	41	0	Misc	0	0	0.00	
Sub Total ==>	307,934	10,778	318,713	79	267,344	63	0	Sub Total ==>	0	0	0.00	
Ceiling Load	2,102	-2,102	0	0	2,248	1	0	Ceiling Load	-2,506	0	0.00	
Ventilation Load	0	0	-51,321	-13	0	0	0	Ventilation Load	0	0	0.00	
Adj Air Trans Heat	0	0	0	0	0	0	0	Adj Air Trans Heat	0	0	0.00	
Dehumid. Ov Sizing	0	0	0	0	0	0	0	Ov/Undr Sizing	0	0	0.00	
Ov/Undr Sizing	0	0	0	0	0	0	0	Exhaust Heat	4,041	-0.90		
Exhaust Heat	0	-2,118	-2,118	-1	0	0	0	OA Preheat Diff.	-245,498	54.46		
Sup. Fan Heat	0	0	19,645	5	0	0	0	RA Preheat Diff.	-4,008	0.89		
Ret. Fan Heat	0	0	0	0	0	0	0	Additional Reheat	-93,945	20.84		
Duct Heat Pkup	0	0	0	0	0	0	0	Underflr Sup Ht Pkup	0	0.00		
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	Supply Air Leakage	0	0.00		
Supply Air Leakage	0	0	0	0	0	0	0					
Grand Total ==>	427,078	7,565	402,967	100.00	423,239	100.00	0	Grand Total ==>	-106,826	-450,809	100.00	

COOLING COIL SELECTION								AREAS			HEA	
	Total Capacity ton	MBh	Sens Cap. MBh	Coil Airflow cfm	Enter DB/WB/HR °F °F	gr/lb	Leave DB/WB/HR °F °F	Gross Total	Glass ft² (%)		Main Htg	Aux Htg
Main Clg	38.6	463.4	393.2	26,520	74.8 62.2	62.6	61.4 56.4	59.2			Preheat	Reheat
Aux Clg	0.0	0.0	0.0	0	0.0 0.0	0.0	0.0 0.0	0.0			Humidif	Opt Vent
Opt Vent	30.5	366.1	173.9	3,633	92.5 78.8	126.1	50.0 49.9	52.9			Total	
Total	69.1	829.5										

		Gross Total		Glass ft² (%)			
Floor	20,489						
Part	0						
Int Door	0						
ExFlr	0						
Roof	0	0	0				
Wall	10,059	3,824	38				
Ext Door	0	0	0				

Project Name: Montgomery College Student Center
Dataset Name: 6352 - ENERGY-062415.TRC

TRACE® 700 v6.3.2
Alternative - 2 Sy

System Checksums

By ACADEMIC

Transient

COOLING COIL PEAK					CLG SPACE PEAK			HEATING COIL PEAK		
Peaked at Time:		Mo/Hr: 10 / 12			Mo/Hr: Sum of		Mo/Hr: Heating Design			
Outside Air:		OADB/WB/HR: 67 / 58 / 56			OADB: Peaks		OADB: 10			
Space Sens. + Lat. Btu/h	Plenum Sens. + Lat. Btu/h	Net Total Btu/h	Percent Of Total (%)		Space Sensible Btu/h	Percent Of Total (%)		Space Peak Space Sens Btu/h	Coil Peak Tot Sens Btu/h	Percent Of Total (%)
Envelope Loads										
Skylite Solar	0	0	0	0	0	0	0	Skylite Solar	0	0.00
Skylite Cond	0	0	0	0	0	0	0	Skylite Cond	0	0.00
Roof Cond	0	332	332	2	0	0	0	Roof Cond	0	19.69
Glass Solar	14,494	0	14,494	89	14,961	92	0	Glass Solar	0	0.00
Glass/Door Cond	-3,139	0	-3,139	-19	-3,529	-22	0	Glass/Door Cond	-1,576	63.15
Wall Cond	-161	-48	-208	-1	-161	-1	0	Wall Cond	-290	15.18
Partition/Door	-3,918	0	-3,918	-24	-3,918	-24	0	Partition/Door	917	-36.76
Floor	0	0	0	0	0	0	0	Floor	-47	1.88
Adjacent Floor	0	0	0	0	0	0	0	Adjacent Floor	0	0.00
Infiltration	0	0	0	0	0	0	0	Infiltration	0	0.00
Sub Total ==>	7,277	284	7,561	47	7,354	45		Sub Total ==>	-996	63.14
Internal Loads										
Lights	5,504	1,376	6,879	42	5,764	36	0	Lights	0	0.00
People	0	0	0	0	0	0	0	People	0	0.00
Misc	410	0	410	3	410	3	0	Misc	0	0.00
Sub Total ==>	5,913	1,376	7,289	45	6,174	38	0	Sub Total ==>	0	0.00
Ceiling Load	1,315	-1,315	0	0	1,266	8	0	Ceiling Load	-563	0.00
Ventilation Load	0	0	126	1	0	0	0	Ventilation Load	0	6.77
Adj Air Trans Heat	0	0	0	0	0	0	0	Adj Air Trans Heat	0	0.00
Dehumid. Ov Sizing	0	0	0	0	0	0	0	Ov/Undr Sizing	-853	34.16
Ov/Undr Sizing	1,382	0	1,382	9	1,382	9	0	Exhaust Heat	102	-4.08
Exhaust Heat	0	-130	-130	-1	0	0	0	OA Preheat Diff.	0	0.00
Sup. Fan Heat	0	0	0	0	0	0	0	RA Preheat Diff.	0	0.00
Ret. Fan Heat	0	0	0	0	0	0	0	Additional Reheat	0	0.00
Duct Heat Pkup	0	0	0	0	0	0	0	Underfir Sup Ht Pkup	0	0.00
Underfir Sup Ht Pkup	0	0	0	0	0	0	0	Supply Air Leakage	0	0.00
Supply Air Leakage	0	0	0	0	0	0	0			
Grand Total ==>	15,886	215	16,227	100.00	16,176	100.00		Grand Total ==>	-2,411	-2,496 100.00

COOLING COIL SELECTION					AREAS			HEA	
Total Capacity ton	Sens Cap. MBh	Coil Airflow cfm	Enter DB/WB/HR °F °F	Leave DB/WB/HR °F °F	Gross Total	Glass ft² (%)			
Main Clg	0.0	0.0	0 0.0 0.0 0.0	0.0 0.0 0.0 0.0	Floor	3,059		Main Htg	
Aux Clg	0.0	0.0	0 0.0 0.0 0.0	0.0 0.0 0.0 0.0	Part	1,200		Aux Htg	
Opt Vent	0.0	0.0	0 0.0 0.0 0.0	0.0 0.0 0.0 0.0	Int Door	0		Preheat	
Total	0.0	0.0			ExFlr	75		Humidif	
					Roof	514	0 0	Opt Vent	
					Wall	419	172 41	Total	
					Ext Door	0	0 0		

Project Name: Montgomery College Student Center
Dataset Name: 6352 - ENERGY-062415.TRC

TRACE® 700 v6.3.2
Alternative - 2 Sys

Emission Factors for On-Site Combustion in a Commercial Boiler

Source: National Renewable Energy Laboratory (2007)

Table 8 Emission Factors for On-Site Combustion in a Commercial Boiler
(lb of pollutant per unit of fuel)

Pollutant (lb)	Commercial Boiler					
	Bituminous Coal *	Lignite Coal **	Natural Gas	Residual Fuel Oil	Distillate Fuel Oil	LPG
	1000 lb	1000 lb	1000 ft ³ ***	1000 gal	1000 gal	1000 gal
CO _{2e}	2.74E+03	2.30E+03	1.23E+02	2.56E+04	2.28E+04	1.35E+04
CO ₂	2.63E+03	2.30E+03	1.22E+02	2.55E+04	2.28E+04	1.32E+04
CH ₄	1.15E-01	2.00E-02	2.50E-03	2.31E-01	2.32E-01	2.17E-01
N ₂ O	3.68E-01	ND [†]	2.50E-03	1.18E-01	1.19E-01	9.77E-01
NO _x	5.75E+00	5.97E+00	1.11E-01	6.41E+00	2.15E+01	1.57E+01
SO _x	1.66E+00	1.29E+01	6.32E-04	4.00E+01	3.41E+01	0.00E+00
CO	2.89E+00	4.05E-03	9.33E-02	5.34E+00	5.41E+00	2.17E+00
VOC	ND [†]	ND [†]	6.13E-03	3.63E-01	2.17E-01	3.80E-01
Lead	1.79E-03	6.86E-02	5.00E-07	1.51E-06	ND [†]	ND [†]
Mercury	6.54E-04	6.54E-04	2.60E-07	1.13E-07	ND [†]	ND [†]
PM10	2.00E+00	ND [†]	8.40E-03	4.64E+00	1.88E+00	4.89E-01

* from the U.S. LCI data module: Bituminous Coal Combustion in an Industrial Boiler (NREL 2005)

** from the U.S. LCI data module: Lignite Coal Combustion in an Industrial Boiler (NREL 2005)

*** Gas volume at 60°F and 14.70 psia.

† no data available

Total Emission Factors for Delivered Electricity

Table 3 Total Emission Factors for Delivered Electricity
(lb of pollutant per kWh of electricity)

Pollutant (lb)	National	Eastern	Western	ERCOT	Alaska	Hawaii
CO _{2e}	1.67E+00	1.74E+00	1.31E+00	1.84E+00	1.71E+00	1.91E+00
CO ₂	1.57E+00	1.64E+00	1.22E+00	1.71E+00	1.55E+00	1.83E+00
CH ₄	3.71E-03	3.59E-03	3.51E-03	5.30E-03	6.28E-03	2.96E-03
N ₂ O	3.73E-05	3.87E-05	2.97E-05	4.02E-05	3.05E-05	2.00E-05
NO _x	2.76E-03	3.00E-03	1.95E-03	2.20E-03	1.95E-03	4.32E-03
SO _x	8.36E-03	8.57E-03	6.82E-03	9.70E-03	1.12E-02	8.36E-03
CO	8.05E-04	8.54E-04	5.46E-04	9.07E-04	2.05E-03	7.43E-03
TNMOC	7.13E-05	7.26E-05	6.45E-05	7.44E-05	8.40E-05	1.15E-04
Lead	1.31E-07	1.39E-07	8.95E-08	1.42E-07	6.30E-08	1.32E-07
Mercury	3.05E-08	3.36E-08	1.86E-08	2.79E-08	3.80E-08	1.72E-07
PM10	9.16E-05	9.26E-05	6.99E-05	1.30E-04	1.09E-04	1.79E-04
Solid Waste	1.90E-01	2.05E-01	1.39E-01	1.66E-01	7.89E-02	7.44E-02